

CLAY School

Clay Joint Elementary School District

12449 S. Smith, Kingsburg, CA 93631

Office:(559)897-4185 FAX:(559)897-2280

One community, One goal; To exceed expectations!



10-29-25

Dear Clay Community,

We are sending you out this notice to inform you that all of our test results for our required Lead and Copper Testing have come back below the action levels established by the EPA. You are welcome to review the following document from the State Water Resources Control Board. Later in the year, you will receive our Consumer Confidence Report that details the results of our required monthly water sampling here on Campus.

Thanks again for your support of Clay!

Eric Medina
Director of MOT

**BOARD OF TRUSTEES: Jeffrey Boldt, John Robert Shepard, Kyle Harrell
Judith Szpor, Superintendent/Principal**



State Water Resources Control Board

Division of Drinking Water

Lead and Copper Tap Sample Results Reporting Form

This form must be submitted by the public water system to the regulating entity (DDW District Office or County Agency) for each round of lead and copper sampling

Report Date: (mm/dd/yyyy)	10/28/25
Water System Name:	CLAY JOINT ELEMENTARY SCHOOL
Water System Number:	CA ~ 1000315
Water System Type:	<input type="radio"/> Community <input checked="" type="radio"/> Non-Transient, Non Community
Monitoring Frequency:	<input type="radio"/> 6-month <input type="radio"/> Annual <input checked="" type="radio"/> Triennial
# of Samples Required:	5
# of Samples Reported:	5
	90th Percentile Level (mg/L)
Lead: <i>Action Level = 0.015 mg/L</i>	0.0015
Copper: <i>Action Level = 1.3 mg/L</i>	0.105

				Result	
	Sample Date	Sample Site Location/Address	Tier 1, 2, 3, or R	Lead (mg/L)	Copper (mg/L)
01	09/30/25	MENS RR LIBRARY	3	ND	0.100
02	09/30/25	NURSES SINK	3	0.0030	0.0040
03	09/30/25	SCIENCE ROOM #15	3	ND	0.110
04	09/30/25	TEACHERS LOUNGE #27	3	ND	0.084
05	09/30/25	2ND. GRADE FAUCET	3	ND	0.016
06					
07					
08					
09					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

Division of Drinking Water
Lead and Copper Tap Sample Results Reporting Form

Sampling Site Change

Each round of sampling should be conducted at the same sampling sites. If an original sampling site is not available, you should collect a tap sample from another site meeting the same Tier criteria as the original site.

You must complete/submit the **Lead and Copper Tap Sampling Site Change** form.

Notification of Results

As required by *40 Code of Federal Regulations Section 141.85(d)*, within 30 days of learning of the tap monitoring results, I notified the participants, by mailing or by another method approved by the State, of the lead sample results from their individual taps, provided an explanation of the health effects of lead, listed steps the consumer could take to reduce exposure to lead, provided contact information for the water utility, the maximum contaminant level goal for lead, action level for lead, and any definitions.

Notification was done on 10/30/2025 by ☐ Direct Mail
(date) ☐ Posting in public area (NTNC systems only)
☒ Other (please specify below)
ParentSquare / Website

For general information on lead and copper tap sampling, you can refer to the **SWRCB Lead and Copper Tap Sample Results Guidance Document**. If you have any questions or comments, please contact your regulating entity (Division of Drinking Water District or County Agency).

SIGNATURE: <u>E. Medina</u>	DATE: <u>10/30/25</u>
NAME (Print): <u>Eric Medina</u>	TITLE: <u>MOT Director</u>